6EP4137-3AB00-2AY0

Data sheet

SITOP UPS1600/DC/24VDC/40A/IE/PN



SITOP UPS1600 40 A Ethernet/ PROFINET Uninterrupted Power supply with Ethernet/ PROFINET interface / OPC UA Server / Web server input: 24 V DC output: 24 V DC/40 A

Input		
supply voltage at DC rated value	24 V	
voltage curve at input	DC	
input voltage range	21 29 V DC	
adjustable response value voltage for buffer connection preset	21.5 V	
adjustable response value voltage for buffer connection	21 25 V; Adjustable: 21 V, 21.5 V, 22 V, 22.5 V, 23 V, 24 V, 25 V DC or via software	
input current at rated input voltage 24 V rated value	46 A; for max. charging current (5 A)	
Mains buffering		
type of energy storage	with batteries	
design of the mains power cut bridging-connection	Adjustable range using rotary coding switch: 0.5 min, 1 min, 2 min, 5 min, 10 min, 20 min, max. buffering time or via software	
charging current	0.1 A, 5 A	
adjustable charging current maximum note	Automatically depending on battery module	
Output		
output voltage		
 in normal operation at DC rated value 	24 V	
in buffering mode at DC rated value	24 V	
formula for output voltage	Vin - approx. 0.2 V	
startup delay time typical	60 s	
voltage increase time of the output voltage typical	60 ms	
output voltage in buffering mode at DC	18.5 27 V	
output current		
• rated value	40 A	
in normal operation	0 120 A	
• in buffering mode	0 120 A	
peak current	120 A	
property of the output short-circuit proof	Yes	
design of short-circuit protection	Limitation to 3 x I rated for 30 ms/min; through-conductivity for 1.5 x I rated for 5 sec/min	
supplied active power typical	960 W	
Efficiency		

efficiency in percent	
 at rated output voltage for rated value of the output current typical 	98.3 %
in case of operation on rechargeable battery typical	98,3 %
power loss [W]	90.3 70
at rated output voltage for rated value of the output current typical	17 W
in case of operation on rechargeable battery typical	17 W
Protection and monitoring	
product function	
reverse polarity protection against energy storage unit polarity reversal	Yes
 reverse polarity protection against input voltage polarity reversal 	Yes
Signaling	
display version	
for normal operation	Normal operation: LED green (OK), floating changeover contact
• in buffering mode	"Bat/OK" to setting "OK" ("OK" means: Voltage of the supplying power supply unit is greater than cut-in threshold set at the DC UPS module); Lack of buffer standby: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Battery replacement required: LED red (alarm) floating with approx. 0.25 Hz, floating changeover contact "Alarm/Bat" switching with approx. 0.25 Hz; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed; Permissible contact current capacity: DC 60 V/1 A or AC 30 V /1 A Buffered mode: LED yellow (Bat), floating changeover contact "OK/Bat" to setting "Bat"; Prewarning battery voltage < 20.4 VDC: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed
	"Bat > 85" Closed
Interface	V
product component PC interface	Yes
design of the interface	Ethernet/PROFINET
design of the interface Safety	Ethernet/PROFINET
design of the interface Safety galvanic isolation between input and output	Ethernet/PROFINET No
design of the interface Safety galvanic isolation between input and output operating resource protection class	Ethernet/PROFINET
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability	Ethernet/PROFINET No Class III
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking	Ethernet/PROFINET No Class III Yes
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEx Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEx Ex nA nC IIC T4 Gc; ATEX (EX) II 3G Ex nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during transport	Ethernet/PROFINET No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2 -25 +70 °C; with natural convection -40 +85 °C
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during transport • during storage	No Class III
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during storage environmental category acc. to IEC 60721	Ethernet/PROFINET No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2 -25 +70 °C; with natural convection -40 +85 °C
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during transport • during storage	No Class III
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during storage environmental category acc. to IEC 60721	No Class III
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during transport • during storage environmental category acc. to IEC 60721 Mechanics	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2 -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation screw-type terminals 24 V DC: 2 screw terminals for 0.5 16 mm²/20 6 AWG
design of the interface Safety galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX • C-Tick type of certification CB-certificate shipbuilding approval protection class IP EMC standard • for emitted interference • for interference immunity environmental conditions ambient temperature • during operation • during transport • during storage environmental category acc. to IEC 60721 Mechanics type of electrical connection	No Class III Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20 EN 55022 Class B EN 61000-6-2 -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation

 for control circuit and status message 	14 screw terminals for 0.2 1.5 mm²/24 16 AWG
width of the enclosure	70 mm
height of the enclosure	139 mm
depth of the enclosure	150 mm
required spacing	
• top	50 mm
• bottom	50 mm
• left	0 mm
• right	0 mm
net weight	0.7 kg
product feature of the enclosure housing can be lined up	Yes
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15
electrical accessories	Battery module
MTBF at 40 °C	318 776 h
reference code acc. to IEC 81346-2	Т
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

